



APPENDIX-VIII

GHAZIABAD MUNICIPAL CORPORATION

Ref. No 1066

/NOB0C0/2024-25

Date 27/12/24

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO 1066/24

Date 27/12/24

It is certified that an Inspection team headed by **NAGAR SWASTHYA ADHIKARI** from **GHAZIABAD MUNICIPAL CORPORATION, HEALTH DEPARTMENT** inspected the Green Field Public School G-Block Govind Puram Ghaziabad-201011 on 12-12-2024 found that Green Field Public School G-Block Govind Puram Ghaziabad-201011 has safe drinking water facilities for the students and members of staff of the institute and is maintaining the hygienic condition in the Institute building & campus as per the norms prescribed by the Central/State/Union Territories Government. Uttar Pradesh Government with this condition that the Institute will follow the Government orders of U P Govt. as U P Plastic & Garbage use and disposal regulatory (Ammended) Rule-2018 & Solid Waste Management- Rule-2016. The said Institute will maintain of the safe potable water, sanitary condition of the Institute.

The above is valid for period of 2024-2025.


NAGAR SWASTHYA ADHIKARI
NAGAR NIGAM GHAZIABAD
नगर स्वास्थ्य अधिकारी
गाजियाबाद नगर निगम


Principal
Green Field Public School
Govind Puram, Ghaziabad


Manager
Green Field Public School
Govindpuram, Ghaziabad

TEST REPORT

Report Issue Date : 17-Dec-2024
Reference Number : 003:W:24:12:00171
Report Number : EQNX:003:W:24:12:00171



Information Provided by Customer

Client Name : Green Field Public School
Address : MFRP+C9V, Block I, G-Block,
Govindpuram, Ghaziabad, Uttar
Pradesh, India-201013
Sampling Location : Ground Floor, Main Room Area
Sample Sub Group : Drinking Water
Sample Name : RO Water
Contact Person : Babita Jha

Particulars of Sample Analysed

Sampling Protocol : SOP-MCB-39-00, SOP-ENV-01-02
Sample Drawn by : Equinox Labs - Sachin Kumar
Quantity & Condition : 1 Ltr. water in a white HDPE bottle and 250ml water in a sterilized plastic bottle. Both bottles are intact without any leaks

Date of Sampling	Date of Receipt	Start Date of Analysis	End Date of Analysis
11-Dec-2024	12-Dec-2024	12-Dec-2024	17-Dec-2024


Result of Analysis

Discipline : Water Group : Biological

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
1	Total Bacterial Count	cfu/ml	IS 1622	$2.2 \times (10)^2$	Not Specified
2	E. coli	/100ml	IS 15185	Not-Detected	Not Detectable
3	Coliform	/100ml	IS 15185	Not-Detected	Not Detectable

Discipline : Chemical Group : Water

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
1	pH - Value at 25°C	-	IS 3025 (Part 11)	7.60	6.5-8.5
2	Taste	-	IS 3025 (Part 8)	Agreeable	Agreeable
3	Odour	-	IS 3025 (Part 5)	Agreeable	Agreeable
4	Electrical Conductivity at 25°C	µS/cm	IS 3025 (Part 14)	142.0	Not Specified


Principal
Green Field Public School
Govind Puram, Ghaziabad


Manager
Green Field Public School
Govindpuram, Ghaziabad

Your Testing and Auditing Partner

TEST REPORT

Report Issue Date : 17-Dec-2024
Reference Number : 003.W:24:12:00171
Report Number : EQNX:003.W:24:12:00171



NABL Scope

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
5	Colour	CU	IS 3025 (Part 4)	<1.0	Max 5
6	Total Alkalinity as CaCO ₃	mg/l	IS 3025 (Part 23)	44.78	Max 200
7	Phenolphthalein Alkalinity	mg/l	IS 3025 (Part 23)	<1.0	Not Specified
8	Total Hardness as CaCO ₃	mg/l	IS 3025 (Part 21)	40.40	Max 200
9	Chloride as Cl	mg/l	IS 3025 (Part 32)	27.59	Max 250
10	Calcium as Ca	mg/l	IS 3025 (Part 40)	9.71	Max 75
11	Magnesium as Mg	mg/l	IS 3025 (Part 46)	3.93	Max 30
12	Reactive Silica	mg/l	IS 3025 (Part 35)	<1.0	Not Specified
13	Sulphate as SO ₄	mg/l	IS 3025 (Part 24) Section 1	<1.0	Max 200
14	Total Dissolved Solids at 180°C	mg/l	IS 3025 (Part 16)	112.0	Max 500
15	Turbidity	NTU	IS 3025 (Part 10)	<1.0	Max 1

Remark : 1. The sample conforms to IS 10500 : 2012 (Acceptable limits) for the parameters tested.

Ruchita

Ruchita Gupta
Assistant Manager - Microbiology
(Authorised Signatory)



Gunjan

Sr. Chemist - Chemistry
(Authorised Signatory)
Gunjan Rajput

Note:

- This Report is Valid for the tested sample only
- Test report shall not be reproduced except in full & with written approval of Equinox Labs Private Limited.
- This report should not be used for advertisement / judicial purpose.
- The information provided by customer can affect the validity of results



Download Report

----- End Of Report -----

I. K. Kaur
Principal
Green Field Public School
Govind Puram, Ghaziabad

Manu
Manager
Green Field Public School
Govindpuram, Ghaziabad

Your Testing and Auditing Partner

Equinox Labs Private Limited | CIN No. U74999MH2017PTC297024

Corporate Office: Equinox Center, R65, TTC, Rabale, Navi Mumbai - 400701

Laboratories At: Mumbai, Bengaluru, Hyderabad, Noida, Kolkata, Chennai

+91 22 50647422

info@equinoxlab.com

www.equinoxlab.com